

August 2004

SDR 32.5

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
4	5 ¹ / ₂	4.500	4.20	0.138	130
6	7 ³ / ₄	6.625	6.18	0.204	280

SDR 27.6

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
6 ¹ / ₄	7 ¹ / ₂	6.900	6.38	0.250	350

SDR 26

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
4	5 ¹ / ₂	4.500	4.14	0.173	160
4 ¹ / ₂	5 ³ / ₄	4.950	4.55	0.190	190
5	6 ⁵ / ₈	5.563	5.11	0.214	240
6	7 ³ / ₄	6.625	6.09	0.255	340
8	9 ³ / ₄	8.625	7.93	0.332	580
10	12 ¹ / ₈	10.750	9.88	0.413	900
12	14 ³ / ₈	12.750	11.72	0.490	1270

SDR 21

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
4	5 ¹ / ₂	4.500	4.05	0.214	190
4 ¹ / ₂	5 ³ / ₄	4.950	4.46	0.236	230
5	6 ⁵ / ₈	5.563	5.01	0.265	290
6	7 ³ / ₄	6.625	5.96	0.316	420
6 ¹ / ₈	7 ¹ / ₂	6.900	6.21	0.329	450
8	9 ³ / ₄	8.625	7.76	0.411	710
10	12 ¹ / ₈	10.750	9.68	0.512	1110
12	14 ³ / ₈	12.750	11.48	0.607	1560

General Notes:

1. Well casing pipe conforms to the requirements of ASTM F 480 and carries a IC-0 impact classification.
2. Except for 4¹/₂" , 6¹/₈" , and 6¹/₄" products, the pipe also meets ASTM D 1785 or ASTM D 2241 for pressurized applications.
3. The pipe meets the requirements of ANSI/NSF Standard 61 as certified by NSF or Underwriters Laboratories, Inc.®.
4. Approximate weights are for estimating purposes only.
5. All orders are subject to final acceptance by PWEagle sales management.

SDR 17

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
4 ^{1/2}	5 ^{3/4}	4.950	4.34	0.291	280
5	6 ^{5/8}	5.563	4.88	0.327	360
6	7 ^{3/4}	6.625	5.81	0.390	510

Schedule 40

Nominal Pipe Size (inches)	Maximum Bell Outside Diameter (inches)	Average Outside Diameter (inches)	Approximate Inside Diameter (inches)	Minimum Wall Thickness (inches)	Approximate Weight (lbs/100')
4	5 ^{1/2}	4.500	4.00	0.237	220
4 ^{1/2}	5 ^{3/4}	4.950	4.43	0.248	240
5	6 ^{5/8}	5.563	5.02	0.258	290
6	7 ^{3/4}	6.625	6.04	0.280	370
8	9 ^{3/4}	8.625	7.95	0.322	590
10	12 ^{1/8}	10.750	9.98	0.365	780
12	14 ^{3/8}	12.750	11.90	0.406	1030

General Notes:

1. Well casing pipe conforms to the requirements of ASTM F 480 and carries a IC-0 impact classification.
2. Except for 4^{1/2"}, 6^{1/8"}, and 6^{1/4"} products, the pipe also meets ASTM D 1785 or ASTM D 2241 for pressurized applications.
3. The pipe meets the requirements of ANSI/NSF Standard 61 as certified by NSF or Underwriters Laboratories, Inc.®.
4. Approximate weights are for estimating purposes only.
5. All orders are subject to final acceptance by PWEagle sales management.